

SUBMITTAL

Part Number
2010096

SUBMITTED TO _____
COMPANY _____
JOB NAME _____
EQUIPMENT _____
SIGNATURE _____
DATE _____

SUBMITTAL		REVISIONS																																							
ZONE	REV.	DESCRIPTION	DATE	APPROVED																																					
FEATURES: - ONE PIECE WELDED CONSTRUCTION - CURB ADAPTER MADE OF HEAVY GAUGE GALVANIZED STEEL. - ALL WELDS ARE COATED WITH A GALVANIZED COMPOUND. - GASKETING IS PROVIDED FOR UNIT TO CURB ADAPTER SEALING. - CURB ADAPTER IS FULLY INSULATED. - SUPPLY TRANSITION AND RETURN PLENUM INCLUDED. Approved By: _____ Date: _____ MATERIAL: 18GA,(0.0516) 209.9 LBS.																																									
Cambridgeport NORTH: 8 Farman Drive, Salisbury Industrial Park, Salisbury MA 01902 1-800-648-2872 SOUTH: 2529 Lamar Ave., Lamar Industrial Park, Memphis TN 38118 1-877-648-2872 HVAC Accessories & Engineered Systems <table border="1"> <tr> <td>UNLESS OTHERWISE SPECIFIED:</td> <td>CUST. JOB NO.</td> <td>DRAWN</td> <td>JSL</td> <td>DATE</td> <td>DESCRIPTION</td> </tr> <tr> <td>TOLERANCES: DECIMALS = ± .003 FRACTIONS = ± 1/16 ANGLES = ± 1°</td> <td>CUST. JOB NO.</td> <td>CARRIER 48DR012 (10A)</td> <td>DATE: 3/18/2019</td> <td></td> <td>ASS'Y, ADAPTER</td> </tr> <tr> <td>MATERIAL CONDITIONS: REMOVE ALL BURRS & SHARP EDGES ALL DIMENSIONS ARE O.D.</td> <td>DATE</td> <td>NEW CARRIER 48HC14 (74A)</td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td>SUBMITTAL</td> <td>2010096</td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td>DETAIL OF</td> <td>2010096</td> <td>SHEET 1</td> <td>CF 1</td> <td>PART NO. 2010096</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> <td>REV.</td> </tr> </table>						UNLESS OTHERWISE SPECIFIED:	CUST. JOB NO.	DRAWN	JSL	DATE	DESCRIPTION	TOLERANCES: DECIMALS = ± .003 FRACTIONS = ± 1/16 ANGLES = ± 1°	CUST. JOB NO.	CARRIER 48DR012 (10A)	DATE: 3/18/2019		ASS'Y, ADAPTER	MATERIAL CONDITIONS: REMOVE ALL BURRS & SHARP EDGES ALL DIMENSIONS ARE O.D.	DATE	NEW CARRIER 48HC14 (74A)					SUBMITTAL	2010096					DETAIL OF	2010096	SHEET 1	CF 1	PART NO. 2010096						REV.
UNLESS OTHERWISE SPECIFIED:	CUST. JOB NO.	DRAWN	JSL	DATE	DESCRIPTION																																				
TOLERANCES: DECIMALS = ± .003 FRACTIONS = ± 1/16 ANGLES = ± 1°	CUST. JOB NO.	CARRIER 48DR012 (10A)	DATE: 3/18/2019		ASS'Y, ADAPTER																																				
MATERIAL CONDITIONS: REMOVE ALL BURRS & SHARP EDGES ALL DIMENSIONS ARE O.D.	DATE	NEW CARRIER 48HC14 (74A)																																							
	SUBMITTAL	2010096																																							
	DETAIL OF	2010096	SHEET 1	CF 1	PART NO. 2010096																																				
					REV.																																				

FEATURES

- ONE PIECE WELDED CONSTRUCTION
- FACTORY INSTALLED SUPPLY TRANSITIONS
- FULLY INSULATED
- DESIGNED FOR EVEN WEIGHT DISTRIBUTION
- FABRICATED OF HEAVY GAUGE G90 GALVANIZED STEEL
- ALL WELDS SPRAYED WITH GALVANIZING COMPOUND
- GASKET PROVIDED FOR UNIT TO ADAPTER SEALING

CAMBRIDGEPORT STRONGLY RECOMMENDS CONFIRMING THE DIMENSIONS ON THIS SUBMITTAL

CURB ADAPTERS ARE BASED ON UNIT MANUFACTURERS STANDARD CURB DIMENSIONS.
CAMBRIDGEPORT CANNOT BE RESPONSIBLE FOR ANY DEVIATIONS FROM FACTORY DIMENSIONS OR INCORRECT MODEL NUMBERS.