

SUBMITTAL

Part Number
2014759

SUBMITTED TO _____
COMPANY _____
JOB NAME _____
EQUIPMENT _____
SIGNATURE _____
DATE _____

REVISIONS	
ZONE	REV. DESCRIPTION DATE APPROVED

© 2007 COX ENGINEERING DBA CAMBRIDGEPORT AIR SYSTEMS. THE INFORMATION CONTAINED IN THIS DOCUMENT IS PROPRIETARY TO COX ENGINEERING COMPANY DBA CAMBRIDGEPORT AIR SYSTEMS. THIS DOCUMENT OR THE INFORMATION CONTAINED IN WHOLE OR IN PART MAY NOT BE ISSUED TO ANOTHER PARTY WITHOUT WRITTEN CONSENT AND AUTHORIZATION FROM CAMBRIDGEPORT.

SUBMITTAL

Approved By: _____
Date: _____

FEATURES:

- ONE PIECE WELDED CONSTRUCTION
- CURB ADAPTER MADE OF HEAVY GAUGE GALVANIZED STEEL.
- ALL WELDS ARE COATED WITH A GALVANIZED COMPOUND.
- GASKETING IS PROVIDED FOR UNIT TO CURB ADAPTER SEALING.
- CURB ADAPTER IS FULLY INSULATED.
- SUPPLY TRANSITION AND RETURN PLENUM INCLUDED.
- BLANK-OFF PANEL SHIPPED LOOSE FOR FIELD INSTALLATION.

MATERIAL: 16GA.(0.0635) 311.3 LBS.

Cambridgeport		NORTH 8 Farnham Drive Salem, MA 01962		1-800-648-2872 1-877-648-2872		SOUTH 2528 Lamar Ave. Memphis TN 38118	
HVAC Accessories & Engineered Systems							
UNLESS OTHERWISE SPECIFIED:		CUST. JOB NO.		DATE:		DRAWN: RTG	
TOLERANCES:		DECIMALS = ± .003		FRACTIONS = ± 1/16		ANGLES = ± 1°	
MATERIAL CONDITIONS:		REMOVE ALL BURRS & SHARP EDGES		ALL DIMENSIONS ARE O.D.		DESCRIPTION: ASS'Y, ADAPTER	
SUBMITTAL: 43503		DETAIL OF: 2014759		SHEET 1 OF 1		PART NO. 2014759	

FEATURES

- ONE PIECE WELDED CONSTRUCTION
- FACTORY INSTALLED SUPPLY TRANSITIONS
- FULLY INSULATED
- DESIGNED FOR EVEN WEIGHT DISTRIBUTION
- FABRICATED OF HEAVY GAUGE G90 GALVANIZED STEEL
- ALL WELDS SPRAYED WITH GALVANIZING COMPOUND
- GASKET PROVIDED FOR UNIT TO ADAPTER SEALING

CAMBRIDGEPORT STRONGLY RECOMMENDS CONFIRMING THE DIMENSIONS ON THIS SUBMITTAL

CURB ADAPTERS ARE BASED ON UNIT MANUFACTURERS STANDARD CURB DIMENSIONS.
CAMBRIDGEPORT CANNOT BE RESPONSIBLE FOR ANY DEVIATIONS FROM FACTORY DIMENSIONS OR INCORRECT MODEL NUMBERS.