

SUBMITTAL

Part Number
2015779



SUBMITTED TO _____
COMPANY _____
JOB NAME _____
EQUIPMENT _____
SIGNATURE _____
DATE _____

REVISIONS	
ZONE	REV. DESCRIPTION DATE APPROVED

© 2018 COX ENGINEERING DBA CAMBRIDGEPORT AIR SYSTEMS. THE INFORMATION CONTAINED IN THIS DOCUMENT IS PROPRIETARY TO COX ENGINEERING COMPANY DBA CAMBRIDGEPORT AIR SYSTEMS. THE DOCUMENT OR THE INFORMATION CONTAINED IN WHOLE OR IN PART MAY NOT BE ISSUED TO ANOTHER PARTY WITHOUT WRITTEN CONSENT AND AUTHORIZATION FROM CAMBRIDGEPORT.

SUBMITTAL

REVISIONS

FEATURES:

- ONE PIECE WELDED CONSTRUCTION
- CURB ADAPTER MADE OF HEAVY GAUGE GALVANIZED STEEL.
- ALL WELDS ARE COATED WITH A GALVANIZED COMPOUND.
- GASKETING IS PROVIDED FOR UNIT TO CURB ADAPTER SEALING.
- CURB ADAPTER IS FULLY INSULATED.
- SUPPLY TRANSITION AND RETURN PLENUM INCLUDED.

Approved By: _____
Date: _____

Cambridgeport
4 CARLETON DRIVE
GEORGETOWN, MA 01833
1-800-648-CURB(2872)
1-978-465-8481

HVAC Accessories & Engineered Systems

UNLESS OTHERWISE SPECIFIED	CUST.	DRAWN	BY	DATE	DESCRIPTION
TOLERANCES: DECIMALS = ± .003 FRACTIONS = ± 1/16 ANGLES = ± 1°	TRANE YCD090-120C (022)	DATE: 04/25/19			ASS'Y, ADAPTER
MATERIAL CONDITIONS: REMOVE ALL BURRS & SHARP EDGES ALL DIMENSIONS ARE O.D.	NEW AAON RN025 STD.	SUBMITTAL: 47611			
	DETAIL OF 2015779	SHEET 1 OF 1			PART NO. 2015779

MATERIAL: 18GA.(0.0516) 165.6 LBS.

FEATURES

- ONE PIECE WELDED CONSTRUCTION
- FACTORY INSTALLED SUPPLY TRANSITIONS
- FULLY INSULATED
- DESIGNED FOR EVEN WEIGHT DISTRIBUTION
- FABRICATED OF HEAVY GAUGE G90 GALVANIZED STEEL
- ALL WELDS SPRAYED WITH GALVANIZING COMPOUND
- GASKET PROVIDED FOR UNIT TO ADAPTER SEALING

CAMBRIDGEPORT STRONGLY RECOMMENDS CONFIRMING THE DIMENSIONS ON THIS SUBMITTAL

CURB ADAPTERS ARE BASED ON UNIT MANUFACTURERS STANDARD CURB DIMENSIONS.
CAMBRIDGEPORT CANNOT BE RESPONSIBLE FOR ANY DEVIATIONS FROM FACTORY DIMENSIONS OR INCORRECT MODEL NUMBERS.